

APPROVAL FOR CONSTRUCTION

THE PLANS AND SPECIFICATIONS FOR SEWAGE
OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

Owner:

James Piper
6 Grove Rd.
Rye, NH 03870

APPROVAL # 117577

LOT NUMBERS: n/a
SUBD. APPVL.#: n/a
SUBD. NAME:

Copy of Plan & Approval sent to:

Joseph May, BI
Town Office
Rye, NH 03870

TYPE OF SYSTEM:

4 bdr.

TOWN/CITY LOCATION:

Rye
Grove Rd.

STREET LOCATION:

By Applicant: PERMIT # 348

Anne W. Bialobrzewski
247 Landing Rd.
Hampton, NH 03842

PLEASE POST IN A CONSPICUOUS PLACE
DURING CONSTRUCTION.

THIS APPROVAL DOES NOT SUPERCEDE
ANY EQUIVALENT OR MORE STRINGENT
LOCAL ORDINANCES OR REGULATIONS.
STATE STANDARDS ARE MINIMAL
AND MUST BE MET STATEWIDE.

WHITE= Applicant's; YELLOW= Town's; BLUE= NHWS&PCC file; GOLD= Owner's - (No Action Required)

NOTE: () Gravity system () Gravity system to septic tank and effluent pump chamber
with disposal system to be constructed on a properly prepared base.

Bed bottom to be set: (X) no deeper than 30" below the original grade
() no less than " above the original grade
() no lower than the original grade

to maintain (X) 4' minimum above (the reported) (any) seasonal high water table.
() ' minimum above (the reported) (any) ledge depth.
(X) 6' minimum above (the reported) (any) impermeable soil.

() Fill to prepare disposal area should be a medium to coarse sand (0.5 to 1.0 mm).
() This approval only valid for the above owner's domicile/exemption.

CONDITIONS: 1. See note on plans indicating that system is not designed to
handle garbage disposal waste.

2. Existing well to be abandoned as per plan.

ADVISE YOUR CONTRACTOR
OF REQUIRED CHANGES IN
PLANS AS INDICATED ON THIS
CONDITIONAL APPROVAL.

are approved this date: 12/14/84

James E. Shepard/blw

revised 8/1/80

By:

James Shepard
N.H. Water Supply & Pollution Control
Commission Staff (OVER)

PERC TEST

DATE: 11/8/84

DEPTH OF HOLE: 30"

RATE OF PERC: 2 MIN/IN

DESIGN LOADING: 4 BEDROOMS

AREA REQUIRED: 750 SQ. FT.

PROPOSED SYSTEM: 25x35 FOR
875 SQ. FT. AREA PROVIDED

PLAN OF PROPOSED SEPTIC SYSTEM FOR EXISTING HOUSE

LOCUS: 6 GROVE ROAD
RYE, NH

OWNER: JAMES PIPER
6 GROVE ROAD
RYE, NH 03870

APPLICANT: ANNE W. BIALOBRZESKI
247 LANDING ROAD
HAMPTON, N.H. 03842
DESIGNER PERMIT #348

DATE: 11/30/84

APPROVAL:


REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
NEW HAMPSHIRE
WATER SUPPLY & POLLUTION
CONTROL COMMISSION

Signed

Date

117577

ADVISE YOUR CONTRACTOR
OF REQUIRED CHANGES IN
PLANS AS INDICATED ON THIS
CONDITIONAL APPROVAL



DEC 11 1984
WATER SUPPLY & POLLUTION
CONTROL COMMISSION

23